

WF Report No. 182094

Page 1 of 2

22nd April 2009

Mr G Franssen

Soudal NV
Everdongenlaan 18-20
B-2300
Turnhout
Belgium

Review of Assessment Report Referenced WFRC No. C113610

1 Introduction

The assessment referenced WFRC No. C113610 provides an opinion regarding the expected fire resistance performance of linear gap sealing systems if tested utilising the principles of BS 476: Part 20: 1987.

The expected fire performance of each seal under consideration is tabulated in Annex A of the assessment.

2 Confirmation of Specification

It has been confirmed by Soudal NV that there have been no changes to the specification of the construction considered in the original appraisal referenced WFRC No. C113610.

3 Conclusions

The data used for the original appraisal has been re-examined and found to be satisfactory.

The procedures adopted for the original assessment have also been re-examined and are similar to those currently in use.

Therefore, with respect to the assessment of performance given in WFRC No. C113610, the contents should remain valid until the 1st May 2014.

4 Validity

This review is based on information used to formulate the original assessment. No other information or data has been provided by Soudal NV which could affect this review.

The original appraisal report was performed in accordance with the principles of the UK Fire Test Study Group Resolution 64A: 1993, which has since been superseded by Resolution 82: 2001. This review has therefore also been conducted using the principles of Resolution 82: 2001.

Performed by:

Reviewed By:



D. Hankinson
Senior Certification



A. Kearns
Technical Manager

This copy has been produced from a .pdf format electronic file that has been provided by Bodycote **warringtonfire** to the sponsor of the report and must only be reproduced in full. Extracts or abridgements of reports must not be published without permission of Bodycote **warringtonfire**. The original signed paper version of this report is the sole authentic version. Only original paper versions of this report bear authentic signatures of the responsible Bodycote **warringtonfire** staff.