

# Declaration of Conformity

## Manufacturers Declaration

In compliance with the Directive 89/106/EEC of the Council of European Communities dated December 21<sup>st</sup> 1988 on the harmonisation of Laws, Regulations and Administrative provisions of the Members States relating to the Construction Products amended by the Directive 93/68/EEC of the Council of European Communities dated 22<sup>nd</sup> 1993 **it is declared** that the Construction Products comply:

### Contego International HS Intumescent Fire Barrier Paint

Manufactured by:  
Contego International, Inc.  
334 West Greyhound Pass  
Carmel, IN 46032  
USA



Under a quality assurance programme.

Marketed by:  
EOV Sverige AB  
Hyvelvägen 3  
444 32 Stenungsund  
Sverige

With the following Classification for Reaction to Fire as defined by EN 13501-1:2007 + A1:2009:

**B-s1,d0**

The Initial Type-Testing for the relevant characteristics of the product was performed by the following approved body:

The Building Test Centre  
East Leake  
Loughborough  
Leicestershire  
LE12 6NP

The following test & classification reports contain the data relating to the tests performance for the declared reaction to fire classification under EN 13501-1:2007 + A1:2009

**BTC 18237FC, BTC 18236F & BTC 18235F**